



Attestation No. 004.03.2012

TELL-Classification

According to the Classification Scheme for Energy Efficiency Labelling of Thermostatic Radiator Valves by EUnited Valves, Brussels, dated 26.04.2011

Manufacturer	GIACOMINI SpA Via per Alzo, 39 28017 San Maurizio d'Opaglio (NO) Italy
Manufacturing plant	Same as Manufacturer
Product	Thermostatic Radiator Valve
Model/Type	Head with integral sensor: R460 DN 15 angle valve: R401D
<u>Influence of water temperature</u>	0,90 K
<u>Hysteresis</u>	0,35 K
<u>Response time</u>	26 min
<u>Influence of differential pressure</u>	0,40 K
<u>Energy Efficiency Indicator</u>	0,50
The corresponding type Test Report according to EN 215	01819RP12
Date of issue	07.03.2012 (Please use this date when applying for the online registration)

Piacenza, 12.03.2012

.....
Ing. Gustavo Cattadori
Director of Operation

.....
Ing. Andrea Achilli
Test Manager